

**Boil Water Notice Rescinded
LIFTED
06/05/2026**

******BLOCKER CROSSROADS WATER SUPPLY CUSTOMERS ******

On JUNE 2, 2026, the Texas Commission on Environmental Quality required the BLOCKER CROSSROADS Water Supply, public water system, PWSTX1020077, to issue a Boil Water Notice to inform customers, individuals, or employees that due to conditions which occurred recently in the public water system, the water from this public water system was required to be boiled prior to use for drinking water or human consumption purposes.

The public water system has taken the necessary corrective actions to restore the quality of the water distributed by this public water system used for drinking water or human consumption purposes and has provided TCEQ with laboratory test results that indicate that the water no longer requires boiling prior to use as of June 5, 2026

If you have questions concerning this matter, you may contact Angelia Mason at 903-633-2250 or our Operator: Colton at 903-399-1144

The water line broken by the land clearing company on June 2, 2026 was repaired, has been thoroughly flushed and has been tested and results for samples taken to the lab on June 4, 2026 show the water is safe.

TCEQ Microbial Reporting Form (TCEQ-10525)

Form Instructions: www.tceq.texas.gov/industrial/industrialwater/default.asp

Water System Identification & Sample Collection Information (Please print or type the information)

System ID: (Include all zeros)	TX	1	0	2	0	0	7	7
System Name:	BLOKKER CROSSROADS WSC					County:	HARRISON	

Angelia Mason-BOWSC

PO BOX 60

ELYSIAN FIELDS	State:	TX	Zip Code:	75642
903-633-2250	PWS Email:	waterdept2019@gmail.com		

NETHEALTH

Northwest Texas Public Health District Regional Laboratory
815 N. Broadway Tyler, Texas 75702
Phone: 903-535-0092 / Fax: 903-535-0097

TCEQ Laboratory ID:
T10470438

Laboratory Analysis

Sample tested?	Yes ☒ No ☐	Temperature (°C)	Actual Temp: 11.5°C	Covered Temp: 11.5°C	RT #:	3
Incubation Date and Time	JUN 04 2026 14:26					
Lab Request Code (LR) - Document I	AB					

Start Date:	JUN 04 2026	Time:	14:26	Analyst:	AB
End Date:	JUN 05 2026	Time:	08:26	Analyst:	AB

Result Reporting and Approval

*SAMPLES MARKED AS SPECIAL OR CONSTRUCTION CANNOT BE USED AS ROUTINE OR REPEAT SAMPLES

Identification/Location	Sample Type (V one)	Collected	Chlorine Residual	Original Sample Info: Sample ID and Date of Collection (Repeat TSM Run (Replacement))	Replacement	Test Method: ☐ SM 923 Coliform ☒ SM 923 Coliform 16	Analysis Results meet all accreditation requirements 33000 coliforms.	Laboratory Sample ID Number
Well Source ID (E: 612345678)	Routine (Distribution)	Repeat	Free mg/L	Date (MM/DD/YYYY)	Time (HH:MM)	Chlorine Check	Total Coliform	E. coli
Fm 31	X			6/4/26	10:25	Present	Present	Present
Fm 2625	X			6/4/26	10:35	Present	Present	Present
Fm 71		X		6/4/26	10:10	Present	Present	Present

I acknowledge that samples were handled appropriately and all information is accurate. Falsification of this form or tampering with water samples is a crime punishable under state and/or federal law. (Texas Penal Code, Title 4, Chapter 37.10)

Samplers Name	Samplers Signature	Samplers Picono #	Operator License #
Waters Dept 2019@gmail.com	Ben Bow	903-397-1144	660021379

Reported By	Date and Time	Received By	Date and Time
Angelia Mason	6/4/26 11:30	Angelia Mason	6/4/26 12:43

Reported To	Date	Time	By
Ben Bow	6/5/26	08:41	AB

TCEQ Water Supply Division - (512) 239-4691

PC