

**LEAD & COPPER RULE MONITORING AND REPORTING VIOLATION
MANDATORY LANGUAGE - TIER III**

IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER

BLOCKER CROSSROADS WSC PWS 1020077 has violated the monitoring and reporting requirements set by Texas Commission on Environmental Quality (TCEQ) in Chapter 30, Section 290, Subchapter F. Even though these were not emergencies, as our customers, you have the right to know what happened and what we are doing (or did) to correct these situations.

We are required to monitor your drinking water for specific contaminants on a regular basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. During (52) 1st 6M2023, 2ND 6M2022, 1st 6M2022, 2nd 6M2021; (53) 2ND 6M2021, 1st 6M2021, 2nd 6M2020, we did not monitor or test and therefore cannot be sure of the quality of your drinking water during that time.

The table below lists the contaminant(s) we did not properly test for during the last year, how often we are supposed to sample for [these contaminants], how many samples we are supposed to take, how many samples we took, when samples should have been taken, and the date on which the follow-up samples were [or will be] taken.

Contaminant	Required sampling frequency	Number of samples taken	When samples should have been taken	When samples were or will be taken
Lead & Copper sample tap 1 st 6M2023	20 / 6 months	20 (reported late)	Jan 1, 2023 – June 30, 2023	06/19 - 21/2023
Lead & Copper sample tap 2 ND 6M2022	20 / 6 months	0	July 1, 2022 – Dec 31, 2022	06/19 - 21/2023
Lead & Copper sample tap 1 st 6M2022	20 / 6 months	20 (reported late)	Jan 1, 2022 – June 30, 2022	06/21-23/2022
Lead & Copper sample tap 2 ND 6M2021	20 / 6 months	0	July 1, 2021 – Dec 31, 2021	06/21-23/2022
LCR Water Quality Parameter 2 ND 6M2021	4 / 6 months	0	July 1, 2021 – Dec 31, 2021	06/17/2022
LCR Water Quality Parameter 1 st 6M2021	4 / 6 months	0	Jan 1, 2021 – June 30, 2021	06/17/2022
LCR Quality Parameter 2 ND 6M2020	4 / 6 months	0	July 1, 2020 – Dec 31, 2020	06/17/2022

What is being done?

[Corrective actions]: In order to return to compliance we were to collect complete sets of lead and copper sample tap samples and water quality parameter samples and those were collected and we returned to compliance as of 06/17/2022 and 07/21/2023.

We are working to correct the problem. For more information, please contact:

Water System Official: DUSTY GOLDEN

Area code + phone number: 903-930-8772 Date Distribution : DECEMBER 13 2023

This notice is being sent to you by BLOCKER CROSSROADS WSC Public Water System Number: TX 1020077